



PAVUS, a.s.

www.pavus.cz

Notified body 1391, Authorized body AO 216, EGOLF member, Fire testing laboratory
Certification body for products and for quality system certification, Expertises, Inspections

Headquarters: Prosecká 412/74, 190 00 Praha 9, Czech Republic
tel.: +420 286 019 587; fax: +420 286 019 590; e-mail: mail@pavus.cz

Fire testing laboratory: Čtvrť J. Hybeše 879, 391 81 Veselí nad Lužnicí, Czech Republic
tel.: +420 381 477 418; fax: +420 381 477 419; e-mail: veseli@pavus.cz

Order No.: Z210180129
Transacted by / contact: Ladislav Městka /
00420 381 477 416
Date: 2018-03-20

Franz KOLAR GmbH
Katharina Parlow-Grüner, MA
Hollergasse 14
AT 1150 Wien
Austria

SUBJECT: Classification results

A classification protocol according to EN 13501-1 + A1: 2010 (no. PK1-01-18-015-C-0), (in German no. PK1-01-18-015-D-0, (in English no. PK1-01-18-015-E-0) for the product *dukta® Sonar PRO acoustic interior panelling* was carried out in the fire test laboratory PAVUS, a.s. in Veselí nad Lužnicí for Franz KOLAR GmbH, Austria on 2018-03-19.

The classification obtained for the reaction to fire for the product is **C - s2, d0**. The product parameters and end use to which this classification applies and the product description are given in the classification report.

Ladislav Městka
Engineer of the testing laboratory

PAVUS, a.s.
Autorizovaná osoba AO 216
Pobočka
391 81 Veselí nad Lužnicí ☺